

17. On and after the effective date of each subparagraph 1 through 12 for a specific EGU, the applicable owner or operator may choose to not operate required control technology under the following conditions:
 - (i) Restarting an EGU when all EGUs at a facility are down and off-site power is not available (also known as a “Black Start”).
 - (ii) Periods of startup of an EGU according to manufacturing recommendations.
 - (iii) Periods of shutdown of an EGU according to manufacturing recommendations.
 - (iv) Periods of scheduled and/or preventative maintenance of control technology equipment if such maintenance cannot reasonably be performed during a scheduled outage of the respective EGU.
 - (v) Periods of malfunction of EGU and/or control technology equipment.
 - (vi) Any other occasion not covered by subparagraphs 17(i) through (v) as approved by the Division.

18. The requirements of subparagraph 17 do not relieve the owner or operator from the requirement to comply with any other applicable requirements of Georgia Rule for Air Quality Control Chapter 391-3-1.