

Facility Name: **Effingham County Power, LLC**
 City: Rincon
 County: Effingham
 AIRS Number: 04-13-103-00012
 Application #: TV-16716

Date Title V Application Received: April 21, 2006
 Permit No: 4911-103-0012-V-03-1

Program	Review Engineers	Review Managers
SSPP	Nancy Johns	Michelle Keith

Introduction

This narrative is being provided to assist the reader in understanding the content of the attached administrative Title V Permit amendment. Complex issues and unusual items are explained here in simpler terms and/or greater detail than is sometimes possible in the actual permit. This permit amendment is being issued pursuant to: (1) Georgia Air Quality Act, O.C.G.A § 12-9-1, et seq. (2) Georgia Rules for Air Quality Control, Chapter 391-3-1, and (3) Title V of the Clean Air Act Amendments of 1990. Section 391-3-1-.03(10) of the Georgia Rules for Air Quality Control incorporates requirements of Part 70 of Chapter I of Title 40 of the Code of Federal Regulations promulgated pursuant to the Federal Clean Air Act. The primary purpose of this permit amendment is to make administrative changes to the permit. Such administrative changes may include a facility name and/or ownership change and fixing typographical errors. The following narrative is designed to accompany the permit amendment and is presented in the same general order as the permit amendment. It describes the facility receiving the permit amendment, existing permits and the changes being made to the permit. This narrative is intended as an adjunct for the reviewer and to provide information only. It has no legal standing.

I. Facility Description

A. Existing Permits

Table 1 below lists the current Title V permit, and all administrative amendments, minor and significant modifications to that permit, and 502(b)(10) attachments.

Table 1: Current Title V Permit and Amendments

Permit/Amendment Number	Date of Issuance	Comments	
		Yes	No
4911-103-0012-V-03-0	September 28, 2005		X

II. Proposed Amendment

A. Description of Amendment

Administrative corrections made to the original permit which include the following:

- (1) Correcting ORIS Code to 055406 in condition 7.9 (to match the Acid Rain Program Phase II Application), and
- (2) Adding subparagraph (i) to Condition 6.1.7(b). This subparagraph was omitted when transferring information from the transitional PSD permit to the final Title V permit.

The above corrections were requested by the Permittee in a letter dated April 12, 2006 (Application No. 16716).

B. Permit Conditions

Condition 7.9 was changed to correct (and match the Acid Rain Permit Application) the ORIS Code to 055406.

Subparagraph (i) of Condition 6.1.7(b) was added. This subparagraph was omitted when transferring information from the transitional PSD permit (Permit No. 4911-103-0012-P-01-0) to the Final Title V permit (Permit No. 4911-103-0012-V-03-0). This subparagraph restricts exceedances detected by monitoring or record keeping. Subparagraph (i) reads: Any three hour rolling average NO_x emission rate, which exceeds 3.0 ppmvd at 15% oxygen for each combustion turbine.