

# Part 70 Operating Permit Amendment

Permit Amendment No.: **2621-175-0004-V-01-1** Effective Date: **February 16, 2004**

**Facility Name:** **SP Newsprint Company**

**Facility Address** 709 Papermill Road  
Dublin, Georgia 31027 (Laurens County)

**Mailing Address:** P.O. Box 1169  
Dublin, Georgia 31040

**Parent/Holding Company:** SP Newsprint Company

**Facility AIRS Number:** 04-13-175-00004

In accordance with the provisions of the Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq and the Georgia Rules for Air Quality Control, Chapter 391-3-1, adopted pursuant to and in effect under the Act, the Permittee described above is issued an amendment to the Part 70 Operating Permit for:

Modification of monitoring and reporting for Nos. 1 and 2 Power Boiler electrostatic precipitators  
(Source Codes: PB11 and PB21)

This Permit Amendment is conditioned upon compliance with all provisions of The Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq, the Rules, Chapter 391-3-1, adopted and in effect under that Act, or any other condition of this Permit Amendment and Permit No. 2621-175-0004-V-01-0. Unless modified or revoked, this Permit Amendment expires simultaneously with Part 70 Permit No. 2621-175-0004-V-01-0.

This Permit Amendment may be subject to revocation, suspension, modification or amendment by the Director for cause including evidence of noncompliance with any of the above; or for any misrepresentation made in Application No. TV-14297 dated February 12, 2003; any other applications upon which this Permit Amendment or Permit No. 2621-175-0004-V-01-0 are based; supporting data entered therein or attached thereto; or any subsequent submittal or supporting data; or for any alterations affecting the emissions from this source.

This Permit Amendment is further subject to and conditioned upon the terms, conditions, limitations, standards, or schedules contained in or specified on the attached **2** pages, which pages are a part of this Permit Amendment, and which hereby become part of Permit No. 2621-175-0004-V-01-0.

---

Director  
Environmental Protection Division

**Table of Contents**

**PART 4.0 REQUIREMENTS FOR TESTING.....1**  
    4.2 Specific Testing Requirements..... 1

**PART 6.0 OTHER RECORD KEEPING AND REPORTING REQUIREMENTS .....2**  
    6.1 General Record Keeping and Reporting Requirements .....2

**PART 4.0 REQUIREMENTS FOR TESTING**

**4.2 Specific Testing Requirements**

4.2.2 The Permittee shall conduct performance tests as specified by the following table and criteria unless otherwise specified by the Division:  
[391-3-1-.02(2)(a)10]

<b>Equipment</b>	<b>Pollutants</b>
No. 1 Power Boiler (PB1)	PM - annual
No. 2 Power Boiler (PB2)	PM - annual
Gas Turbine (2GT)	NO <sub>x</sub> – annual
Heat Recovery Steam Generator (HRSG)	NO <sub>x</sub> – annual

- a. Deleted
- b. Deleted

**PART 6.0 OTHER RECORD KEEPING AND REPORTING REQUIREMENTS**

**6.1 General Record Keeping and Reporting Requirements**

6.1.7 For the purpose of reporting excess emissions, exceedances or excursions in the report required in Condition 6.1.4, the following excess emissions, exceedances, and excursions shall be reported:

[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]

- c. Excursions: (means for the purpose of this Condition and Condition 6.1.4, any departure from an indicator range or value established for monitoring consistent with any averaging period specified for averaging the results of the monitoring)
  - ii. Deleted
  - iv. Any three consecutive readings during which the total secondary power for the No. 1 Power Boiler electrostatic precipitator (Source Code: PB11) falls below 8,434 watts.
  - v. Any three consecutive readings during which the total secondary power for the No. 2 Power Boiler electrostatic precipitator (Source Code: PB21) falls below 53,099 watts.